



NOTES:

1. FLUSHING PRESSURE TO BE 20 PSIG ABOVE MAX. LINE PRESSURE.
2. LIQUID VELOCITY SHOULD BE AT LEAST 4 FPS FOR BEST RESULTS BUT WILL WORK AT 1.5 FPS AND HIGHER VELOCITIES IF FLUSHING IS USED.
3. CHECK CLEARANCE BEHIND SENSOR FOR REMOVAL-10" REQ.
4. MAX. LINE PRESSURE DESIGN OF 90 PSIG OR 6 BARS.
5. FLOW CAN BE IN EITHER DIRECTION.

ITX-IL VERTICAL & HORIZONTAL MOUNTING DETAILS FOR 4" OR LARGER PIPE		NO. 1 CORRECTED VALVE DIMENSIONS 2 REVISED NIPPLE TO 4" LONG		REV. DATE 5/9/16	
		JLT 11/01/03		5/9/16	
DRAWING NUMBER 140		LAST REV. DATE 5/9/16		SCALE NTS	
Ceric Environmental Controls, Inc P.O. Box 420097 Atlanta, GA 30342 Phone (404) 256-3097 Fax (404) 256-3094		CONTRACTOR TO CHECK		REVISIONS	